



Town of Groveland
Water and Sewer Department
183 Main Street
Groveland, MA 01834
978-372-4144 Fax 978-373-6147

April 28, 2010

Installation of Deduct Meters

Recommended Backflow Device

Description:

Body: Bronze
Disc: Silicone
Pressure: 175 PSI

Springs: Stainless Steel
Temp: 140° F (60° C)

Model PVB Anti-Siphon Pressure Vacuum Breakers prevent backflow of pollutants or contaminated water into the potable water system due to backsiphonage. It consists of bronze body with a silicone rubber check valve disc, stainless steel springs, a ABS corrosion resistant access cover and tee handles or lever handle shutoffs. Model PVB are used in health hazard continuous pressure applications such as irrigation systems in only backsiphonage conditions. *Must be installed 12" above highest outlet in system.*

Typical Installation

